

OFFICE OF THE CHIEF FIRE OFFICER
KARNATAKA FIRE AND
EMERGENCY SERVICES
KALABURAGI ZONE
KALABURAGI-585103

No. 36/CFO-/KLB/NOC/2018

Office of the Chief Fire Officer
Karnataka Fire & Emergency Services
KALABURAGI Zone KALABURAGI,
Date: 27-02-2018

To.

The Principal/ Secretary

Aryan kannada /English medium higher
primary school (CBSE) kotnoor D.layout.
Near naganahalli
cross ring road , Kalaburagi

Sir,

Sub : Renewal of NOC on requirement of fire prevention, fire fighting &
evacuation measures for Aryan kannada /English medium higher
primary school (CBSE) kotnoor D.layout.Near naganahalli
cross ring road , Kalaburagi

Ref: 1. CNO:15 :RFO:KLB:School-Inp:2018, DATE 27-02-2018

With reference to the subject cited above, the premises Aryan kannada
/English medium higher primary school (CBSE) kotnoor D.layout.Near
naganahalli cross ring road , Gulbarga was inspected by me on 27-02-2018 for
suggesting fire prevention, fire fighting and evacuation measures. The details are
as follows .

A. Details of the Building:-

1. Address of the premises : Aryan kannada /English medium higher
primary school (CBSE) kotnoor D.layout.
Near naganahalli cross ring road , Gulbarga

2. Number of Buildings : One Building.

3. Number of floors : Ground + 1 Floor


4. Floor wise details of occupancy

Ground floor : 17 class rooms ,1 principal chamber

1st floor : 18 class rooms


PRINCIPAL
Shankar Singh Memorial Trust
Aryan Kannada / English
Medium Higher Primary School
GULBARGA
C.B.S.E. AFFILIATION No. 830338




SECRETARY
Shankar Singh Memorial Trust
Kalaburagi.

5. Height of the Building : 3.70 mtrs
6. Site area : 10 Acers, 5 Gunte
7. Built-up area
- | | | |
|--------------|---|-----------------|
| Ground floor | : | 2571.07 Sq.mtrs |
| 1st floor | : | 2571.07 Sq.mtrs |
- Total : 5142.14 Sq.mtrs
8. Type of Constructions : R.C.C. Building.
9. Surroundings
- | | | |
|-------|---|--------------------------------|
| East | : | Open area |
| West | : | Open area |
| North | : | Open area & Approach ring road |
| South | : | Open area |
10. Entrance and exist gate : 02 entrance (one is 5.0meter & another one is 8.0 width)
- 11 .Name & Address of the Building Owner : Principal/ President
Aryan kannada /English medium higher primary school (CBSE) kotnoor D.layout.
Near naganahalli cross ring road , Gulbarga
12. Name & Address of the Applicant : -do-
13. (A) Number of Students : 1000 No's
- (B) Number of Employees : 40 No's



[Signature]
PRINCIPAL
Shankar Singh Memorial Trust
Aryan Kannada / English
Medium Higher Primary School
GULBARGA
CBSE AFFILIATION No. 830338

[Signature]
SECRETARY
Shankar Singh Memorial Trust
Kalaburagi.

4. On inspection of the school premises, the following fire prevention, fire fighting and evacuation measures are existing :-

Detail (1)	Existing (2)	Recommendation
1. Approach to the Premise	The premises is accessible from 12.0 mtr Wide road located on the Northern side	Requirement complied with
2. Number of Staircases.	02 staircase have been Provide from ground floor To terrace floor.	Requirement complied with
3 Parking area	provided on northern side of the building	Requirement complied with
4. corridor	: 2.80 meter wide	
5. Open space around the Building:	East : Open space West : Open space North : Open space and road South : Open space	
6. Segregation of the Premises	: Open space all around the school Building belongs the applicant	

7. Portable Fire Extinguishers:-

Provided
Ground floor

04 Nos ABC fire extinguishers
Each of 06 Kgs capacity,
2 no,s CO2 of 4.5 kg capacity

Adequate.



Shankar Singh Memorial Trust
Arya Vidyalaya / English
Medium Higher Primary School
GULBARGA
C.B.S.E. AFFILIATION No. 830338

SECRETARY
Shankar Singh Memorial Trust
Kalaburagi.

1st floor

And 6 fire buckets filled with fine sand
Have been provided.

- 1) 04 Nos ABC fire extinguishers
each of 06 Kgs capacity,
- 2) 1 co2 4.5 kg capacity have been
provided.


(d)Hose reel hose system : Not provided

Recommended to
Provided hose reel hose
system near the
staircases connected to
terrace tank of 10,000
liters capacity ,and the
system connected to
electrical driven pump
of discharge capacity
450LPM


8. Fire Prevention
measures.

Not indicated

- 1). Explosive and
Inflammable materials
Should not be stored
In the premises.
- 2). Accumulation of
Combustible waste in
And around the premises
Should be avoided.
- 3). The class room and
other doors shall not be
Kept locked/latched
During working hours
And shall be free from
Obstructions.
- 4) C.C. cameras to be
provided all around the
school building at the
strategic locations
- 5) Public address system
to be provided though
out the school building
with its console at the
lobby or with
management


PRINCIPAL
Shankar Singh Memorial Trust
Aryan Kannada / English
Medium Higher Primary School
GULBARGA
C.B.S.E. AFFILIATION No. 830335




SECRETARY
Shankar Singh Memorial Trust
Kalaburagi.

9. Escape Route

Directions in which the Students have to move in the event of any emergency have been indicated in the corridor/Staircase, on each floor.(EXIST SIGN BOARD)

The requirement is complied with

10. First Aid Box

One First Aid Box at each Floor has been provided.

11. Fire fighting.

2 person trained In fire fighting at R.A.Mundkur Fire & Emergency Service Academy, Bannerughatta Road, Bangalore.
1) Sri Husen sab
2) ,, timmanna b.k

the requirement is Complied with

12. Fire Order


Notice boards indicating with Details of action to be taken by the employees in case of an Emergency/fire has been displayed with telephone Number of Kalaburagi Fire Station i.e. 08472-220101 & 101 and of near by Ambulance Service.


The requirement is Complied with


Hence this NOC is issued to Aryan kannada /English medium higher primary school (CBSE) kotnoor D.layout.Near naganahalli cross ring road , Gulbarga subject to strict adherence of the conditions laid down in this NOC and to check up the portable fire extinguishers & to conduct mock drills periodically and this NOC is valid a period of one year from the date of issue.

Your's faithfully

Copy to : The Regional Fire Officer Kalaburagi


PRINCIPAL
Shankar Singh Memorial Trust
Medium Higher Primary School
GULBARGA
C.B.S.E. AFFILIATION No. 830338


SECRETARY
Shankar Singh Memorial Trust
Kalaburagi.


CHIEF FIRE OFFICER
KARNATAKA FIRE AND
EMERGENCY SERVICES
KALABURAGI
KALABURAGI-586103